



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA190498

Date of Issue: 5 March 2019

Class Description: Non-Declared

Product Description: PV Inverter (Grid-tied Photovoltaic Inverter)

Additional Models	Description
X1-6.0-T-D	Input: MPP Voltage range: 100-500Vdc, Max 550Vdc, Max 11/22A Output: 230V~ 50Hz, Max 28A, Max 6000VA
X1-6.0-T-N	Input: MPP Voltage range: 100-500Vdc, Max 550Vdc, Max 11/22A Output: 230V~ 50Hz, Max 28A, Max 6000VA
X1-7.0-T-D	Input: MPP Voltage range: 100-500Vdc, Max 550Vdc, Max 11/22A Output: 230V~ 50Hz, Max 32A, Max 7000VA
X1-7.0-T-N	Input: MPP Voltage range: 100-500Vdc, Max 550Vdc, Max 11/22A Output: 230V~ 50Hz, Max 32A, Max 7000VA
X1-8.0-T-N	Input: MPP Voltage range: 100-500Vdc, Max 550Vdc, Max 11/22A Output: 230V~ 50Hz, Max 35A, Max 8000VA

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 05-03-19 190498/2